






# 鉛除去テスト

## 1. テストフロー



## 2. テスト結果

単位：ppm	原液	1パス	3パス	5パス
浄化状況				
固型化鉛	0.2	0.01	0.007	0.005
イオン化鉛	0.011	0.007	0.005	0.005 未満